



Water Distribution System
Annual Summary Report
2025

Managed, Operated and Maintained By:

Jacobs

The Village of Oil Springs

Water Distribution System – 2025 Annual Summary Report

This summary report has been prepared by **OMI (Jacobs)** for the Village of Oil Springs. The purpose of the report is to meet the requirements of the Safe Drinking Water Act, 2002 and Ontario Regulation 170/03, Schedule 22, which requires that a Summary Report be prepared each year no later than March 31st and given to the municipal council in the case of a drinking water system owned by a municipality. Schedule 22-2(1)

The report summarizes the water quality information for the Oil Springs Water Distribution System, for the period of **January 1, 2025, to December 31, 2025**.

The Oil Springs Water Distribution System is categorized as a Large Municipal Residential Drinking Water System. **Water Works # 260046761**.

The MECP Inspection for the Oil Springs Water Distribution System was conducted July 10, 2025.

The overall MECP Inspection rating for 2025 was 100%. There have been no AWQI for 2025

Statement of Compliance:

The Oil Springs Water Distribution System is operated and maintained by **Jacobs** on behalf of The Village of Oil Springs. The water supplied to the consumers serviced by the system follows the requirements of the Safe Drinking Water Act, all applicable regulations made in accordance with the Act, the Municipal Drinking Water Works Permit Number: 251-20, Issue Number: 3 (Jan 6/2022) and the Municipal Drinking Water License Number: 251-101, Issue Number: 4 (Jan 6/2022)

Review of Distribution system:

The Village of Oil Springs is the Owner of the distribution system servicing a population of approximately 698 residents with 298 services.

The Distribution system includes the following:

- 2 water sample stations
- 38 fire hydrants & fire hydrant isolation valves
- 3 blow offs at dead ends
- 74 watermain isolation valves
- 9 residential water meter pits
- 2 in-line water meters which read the amount of water flow received by Oil Springs WDS
- 2 in-line boundary isolation valves connecting the Oil Springs WDS with the Enniskillen WDS.
- The piping size for the distribution system consists of 50 mm to a 300 mm diameter water mains.

The Oil Springs Water Distribution System is supplied by The Township of Enniskillen Water Distribution System. Pressurized water is purchased & received by the Township of Enniskillen via two (2) meter chambers. The Enniskillen Reservoir has pressure monitoring equipment with 24/7 alarm monitoring capabilities. System pressure is checked weekly at the Municipal Office by the Operating Authority's Operators and documented in logbook.

There are no chemicals added to the system by The Village of Oil Springs. Immediately upstream of the system, The Township of Enniskillen provides re-chlorination with a 12% chlorine solution of sodium hypochlorite injected into the Influent flow at the Enniskillen Reservoir. Enniskillen Public Works analyzes chlorine residual at the Reservoir.

Oil Springs Water Distribution System follows O. Reg 170/03 section 7-2 (3) & (4) for its sampling protocol. The Operating Authority collects seven (7) chlorine residual samples per week (4/3 rule)

During the summer months a chlorine residual is analyzed at the Black Creek Golf Course which is located on a dead-end main (Plank Rd) but is only open during the summer months. (May - Oct)

The in-line boundary water meters (2) were calibrated on September 17, 2024, by the Enniskillen Public Works Department. (due again in 2026)

Fire Hydrants are flushed semi-annually during the “spring” & “fall” seasons. Hydrants were flushed in May & October with the associated Hydrant Isolation valves being exercised simultaneously during the May flushing. When the “fall” flushing occurs, the hydrants are pumped out to prevent freezing.

Fire Flows were conducted on all hydrants in 2023 & 2024

2025 Repairs & Maintenance:

- **January** – Operator inspecting throughout Oil Springs (dead-ends, ditches, drains, edges of open fields) for any visible signs of water leaks (puddles, melted snow, accumulation of ice)
- **April** – a water line leak was repaired at 2525 Richmond Street (Al Byers) with the residential water meter pit being relocated up the hill with a new water meter & curb stop being installed.
- **April** – installed a service line & curbstop for a new build at 4589 Victoria St.
- **May** – water valve box was replaced on valve # 32 at 2580 Richmond St.
- **May** – water valve box was replaced on valve # 43 at 2605 Bruce St.
- **July** – installed a 2” water service at 4752 Annaline
- **August** – annual water main isolation valves exercise
- **November** – due to a residential fire, hydrant # 29 was used, Public Works pumped out the hydrant after use.

Water Meters replaced:

- 2594 Hannah St – Ryan Lewis
- 2590 Richmond St – Adam Veen
- 4615 Oil Springs Line – Vladimir
- 4693 Oil Springs Line – Dan Haskell
- 2525 Richmond St – Byers

Complaints:

- **October 27th** – The Village of Oil Springs received a water complaint via email at 5:48 pm from 2797 Oil Heritage Road. The next day the Operating authority received an email from the Municipality on Oct 28th at 08:09 am but did not check emails until 10:16. Operating Authority called homeowner, and they had already flushed there lines (2 separate taps) and the water was clear. Homeowner was not at the residence when call was placed.

Sample Locations in the WDS:

1. **Sample Station # 1** (behind Museum - 2423 Kelly Rd)
2. **Sample Station # 2** (4898 Oil Springs Line - by valve chamber)
3. **Black Creek Golf Course** (4360 South Plank Rd)
4. **Main Pump Station** (2601 Fredrick St)
5. **Hydrant # 34** (Meadowview Estates)
6. **Oil Springs Youth Centre** (4517 Victoria St.)
7. **Oil Springs Municipal Office** (4591 Oil Springs Line)
8. **Oil Springs Community Hall** (4596 Oil Springs Line)
9. **Hydrant # 38** (Gypsie Flat - Dead-end)

Health Samples:

Health samples include tests for the presence of E-coli, Total Coliforms & HPC (Heterotrophic Plate Count) Any presence of E-coli or Total Coliforms would be considered adverse and must be reported. Samples are collected and analyzed weekly. Free Chlorine analysis is also performed at each site when collecting the health samples.

Health samples for HPC (Heterotrophic Plate Count) ranged from: **< 10 cfu/mL to 10 cfu/mL.**

Chlorine residual results less than 0.20 mg/L are of concern and results less than 0.05 mg/L are considered adverse and must be reported. Chlorine residuals collected during sampling ranged from:

- **Highest reading was 1.93 mg/L on November 14th at Main pumping station**
- **Lowest reading was at 0.67 mg/L on September 9th at Sample Station # 1**

The Quarterly THM (Trihalomethane) samples were collected on:

- **Jan 7th at Sample Station # 1, with a result of: 34 ug/L** (2024: 44 ug/L)
- **April 1st at Hydrant # 38, with a result of: 46 ug/L** (2024: 36 ug/L)
- **July 8th at Sample Station # 1, with a result of: 53 ug/L** (2024: 45 ug/L)
- **Oct 7th at Hydrant # 38, with a result of: 60 ug/L** (2024: 55 ug/L)

The Quarterly HAA (Haloacetic Acid) samples were collected at: **Hydrant # 34 (closest to the Chlorine Injection at the Enniskillen Reservoir)**

- **Jan 7th with a result of: 21.6 ug/L** (2024: 39.8 ug/L)
- **April 1st with a result of: 15.6 ug/L** (2024: 23.2 ug/L)
- **July 8th with a result of: 22.6 ug/L** (2024: 25.6 ug/L)
- **Oct 7th with a result of: 16 ug/L** (2024: 19 ug/L)

As per O. Reg 170/03, s15. 1-5: The water distribution system for The Village Oil Springs has qualified for a reduced lead sampling schedule. The 2025 Lead sampling was conducted on **April 1st** (winter period: Dec 15th to April 15th) and **Oct 7th** (summer period: June 15th to Oct 15th) Lead sampling is to commence again in 2028. Also, a sample for pH & alkalinity was analyzed as required (must be sampled & analyzed every year during both sample periods - even if you are on a reduced lead protocol)

2025 Water purchased from Enniskillen Township (m3)

Month	Oil Heritage Road water meter	Oil Springs Line water meter	Monthly Total
January	4766	96	4862
February	4726	55	4781
March	3584	337	3921
April	4097	271	4368
May	4238	317	4555
June	5101	323	5424
July	4760	270	5030
August	5067	153	5220
September	5431	80	5511
October	4519	143	4662
November	4548	63	4611
December	4522	37	4559
		2025 Annual Total	57,504
		Monthly Average	4,792
		Daily Average	157.5

The total amount purchased includes water sold to customers within the Oil Springs Distribution System and other uses, including hydrant flushing, fire flows, watering flowers, new watermain construction, repairs to watermain, flushing lines & water mains during compliance sampling / residual analysis.

Water Purchased		Water Loss Factor	
Year	Amount Purchased	Year	Loss Factor %
2025	57, 504	2025	17.31
2024	58, 230	2024	20.41
2023	57, 736	2023	16.76
2022	54, 595	2022	13.71
2021	51, 399	2021	7.46
2020	51, 219	2020	11.47
2019	45, 595	2019	6.65
2018	47, 235	2018	7.76
2017	46, 167	2017	5.27
2016	50, 751	2016	7.58
2015	50, 959	2015	6.64
2014	49, 823	2014	8.61

The agreement with the Township of Enniskillen provides for the supply of water for an ultimate population of 1200 in the Village of Oil Springs.

The estimates of water consumption are based on a 66 imp. gallons/capita/day (0.3 m3/capita/day) for a population of 1200, the average daily consumption is 79,000 imp. gallons/day (359 m3/day) with an average flow rate of 55 imp.8.21 gpm (0.25 m3/min) Maximum daily flow rate of 138 imp gpm (0.63 m3/min) and a peak hourly flow 8.81rate of 206 imp gpm (0.94 m3/min) 6.63

Oil Springs WD Residuals & Lab Analysis
Jan-25

DD - Derek Daly
CC - Cathy Culnan

	Date	Time	Operator	Sampling Location	Chlorine Residual mg/L	E. coli cfu/1 mL	Total Coliform cfu/1 mL	HPC ug/L	HAA ug/L	THM ug/L	pH	Alkalinity mg/L	Lead ug/L	Lab Report Received	Init.	
Week 1	Set 1			Municipal Office (4591 Oil Springs Line)											CC	
				Sample Station # 1 (2423 Kelly Rd)												
				Youth Centre (4517 Victoria Street)												
				Main Pump Station (2601 Fredrick Street)												
	Set 2	Jan 3rd	7:30 AM	DD	Sample Station # 2 (4898 Oil Springs Line)	1.42										
		Jan 3rd	7:45 AM	DD	Youth Centre (4517 Victoria Street)	1.60										
Jan 3rd		7:15 AM	DD	Main Pump Station (2601 Fredrick Street)	1.58											
Week 2	Set 1	Jan 7th	7:50 AM	DD	Municipal Office (4591 Oil Springs Line)	1.31	0	0	< 10					Jan 10th	CC	
		Jan 7th	9:00 AM	DD	Museum (2423 Kelly Rd)	1.33	0	0	< 10		34					
		Jan 7th	8:20 AM	DD	Hydrant # 34 (Meadowview Estates)	1.48				21.6						
		Jan 7th	7:20 AM	DD	Main Pump Station (2601 Fredrick Street)	1.48										
	Set 2	Jan 10th	7:30 AM	DD	Community Hall (4596 Oil Springs Line)	1.31										
		Jan 10th	7:45 AM	DD	Youth Centre (4517 Victoria Street)	1.26										
Jan 10th		7:15 AM	DD	Main Pump Station (2601 Fredrick Street)	1.24											
Week 3	Set 1	Jan 14th	7:40 AM	DD	Municipal Office (4591 Oil Springs Line)	1.48	0	0						Jan 17th	CC	
		Jan 14th	7:30 AM	DD	Community Hall (4596 Oil Springs Line)	1.52										
		Jan 14th	7:55 AM	DD	Youth Centre (4517 Victoria Street)	1.45	0	0								
		Jan 14th	7:10 AM	DD	Main Pump Station (2601 Fredrick Street)	1.37										
	Set 2	Jan 17th	7:30 AM	DD	Community Hall (4596 Oil Springs Line)	1.38										
		Jan 17th	7:45 AM	DD	Youth Centre (4517 Victoria Street)	1.53										
Jan 17th		7:15 AM	DD	Main Pump Station (2601 Fredrick Street)	1.55											
Week 4	Set 1	Jan 21st	7:40 AM	DD	Municipal Office (4591 Oil Springs Line)	1.53	0	0						Jan 24th	CC	
		Jan 21st	7:30 AM	DD	Community Hall (4596 Oil Springs Line)	1.40	0	0								
		Jan 21st	8:00 AM	DD	Youth Centre (4517 Victoria Street)	1.51										
		Jan 21st	7:10 AM	DD	Main Pump Station (2601 Fredrick Street)	1.49										
	Set 2	Jan 24th	7:30 AM	DD	Community Hall (4596 Oil Springs Line)	1.42										
		Jan 24th	7:45 AM	DD	Youth Centre (4517 Victoria Street)	1.44										
Jan 24th		7:10 AM	DD	Main Pump Station (2601 Fredrick Street)	1.48											
Week 5	Set 1	Jan 28th	7:30 AM	DD	Municipal Office (4591 Oil Springs Line)	1.59	0	0						Jan 31st	CC	
		Jan 28th	7:20 AM	DD	Community Hall (4596 Oil Springs Line)	1.50										
		Jan 28th	7:45 AM	DD	Youth Centre (4517 Victoria Street)	1.49	0	0								
		Jan 28th	7:05 AM	DD	Main Pump Station (2601 Fredrick Street)	1.56										
	Set 2	Jan 31st	8:25 AM	DD	Community Hall (4596 Oil Springs Line)	1.61										
		Jan 31st	8:35 AM	DD	Youth Centre (4517 Victoria Street)	1.55										
Jan 31st		8:15 AM	DD	Main Pump Station (2601 Fredrick Street)	1.62											

Residuals are collected as per O. Reg 170/03 s 7-2 (3) & (4)

Bacteriological samples are collected as per O. Reg 170/03 s 10 (2) & (3)

Oil Springs WD Residuals & Lab Analysis

Feb-25

DD - Derek Daly
CC - Cathy Culnan

	Date	Time	Operator	Sampling Location	Chlorine Residual mg/L	E. coli cfu/1 mL	Total Coliform cfu/1 mL	HPC ug/L	HAA ug/L	THM ug/L	pH	Alkalinity mg/L	Lead ug/L	Lab Report Received	Init.	
Week 1	Set 1	Feb 4th	7:45 AM	DD	Municipal Office (4591 Oil Springs Line)	1.56	0	0	< 10					Feb 7th	CC	
		Feb 4th	7:30 AM	DD	Community Hall (4596 Oil Springs Line)	1.43										
		Feb 4th	8:00 AM	DD	Youth Centre (4517 Victoria Street)	1.56	0	0	< 10							
		Feb 4th	7:15 AM	DD	Main Pump Station (2601 Fredrick Street)	1.61										
	Set 2	Feb 7th	7:30 AM	DD	Community Hall (4596 Oil Springs Line)	1.42										
		Feb 7th	7:45 AM	DD	Youth Centre (4517 Victoria Street)	1.46										
		Feb 7th	7:15 AM	DD	Main Pump Station (2601 Fredrick Street)	1.58										
	Week 2	Set 1	Feb 11th	7:35 AM	DD	Municipal Office (4591 Oil Springs Line)	1.49								Feb 14th	CC
Feb 11th			7:25 AM	DD	Community Hall (4596 Oil Springs Line)	1.51	0	0								
Feb 11th			7:50 AM	DD	Youth Centre (4517 Victoria Street)	1.46	0	0								
Feb 11th			7:10 AM	DD	Main Pump Station (2601 Fredrick Street)	1.56										
Set 2		Feb 14th	7:30 AM	DD	Community Hall (4596 Oil Springs Line)	1.70										
		Feb 14th	7:45 AM	DD	Youth Centre (4517 Victoria Street)	1.59										
		Feb 14th	7:15 AM	DD	Main Pump Station (2601 Fredrick Street)	1.61										
Week 3		Set 1	Feb 19th	7:35 AM	DD	Municipal Office (4591 Oil Springs Line)	1.83	0	0						Feb 21st	CC
	Feb 19th		7:25 AM	DD	Community Hall (4596 Oil Springs Line)	1.75										
	Feb 19th		7:50 AM	DD	Youth Centre (4517 Victoria Street)	1.72	0	0								
	Feb 19th		7:10 AM	DD	Main Pump Station (2601 Fredrick Street)	1.74										
	Set 2	Feb 21st	8:20 AM	DD	Community Hall (4596 Oil Springs Line)	1.72										
		Feb 21st	8:40 AM	DD	Youth Centre (4517 Victoria Street)	1.80										
		Feb 21st	8:05 AM	DD	Main Pump Station (2601 Fredrick Street)	1.71										
	Week 4	Set 1	Feb 25th	7:30 AM	DD	Municipal Office (4591 Oil Springs Line)	1.75								Feb 28th	CC
Feb 25th			7:20 AM	DD	Community Hall (4596 Oil Springs Line)	1.67	0	0								
Feb 25th			7:45 AM	DD	Youth Centre (4517 Victoria Street)	1.72	0	0								
Feb 25th			7:05 AM	DD	Main Pump Station (2601 Fredrick Street)	1.73										
Set 2		Feb 28th	7:25 AM	DD	Community Hall (4596 Oil Springs Line)	1.58										
		Feb 28th	7:40 AM	DD	Youth Centre (4517 Victoria Street)	1.63										
		Feb 28th	7:10 AM	DD	Main Pump Station (2601 Fredrick Street)	1.70										
Week 5		Set 1				Municipal Office (4591 Oil Springs Line)										
					Community Hall (4596 Oil Springs Line)											
					Youth Centre (4517 Victoria Street)											
					Main Pump Station (2601 Fredrick Street)											
	Set 2				Community Hall (4596 Oil Springs Line)											
					Youth Centre (4517 Victoria Street)											
					Main Pump Station (2601 Fredrick Street)											

Residuals are collected as per O. Reg 170/03 s 7-2 (3) & (4)

Bacteriological samples are collected as per O. Reg 170/03 s 10 (2) & (3)

Oil Springs WD Residuals & Lab Analysis
Mar-25

DD - Derek Daly
CC - Cathy Culnan

	Date	Time	Operator	Sampling Location	Chlorine Residual	E. coli	Total Coliform	HPC	HAA	THM	pH	Alkalinity	Lead	Lab Report	Init.	
					mg/L	cfu/1 mL	cfu/1 mL	ug/L	ug/L	ug/L		mg/L	ug/L	Received		
Week 1	Set 1	March 4th	7:35 AM	DD	Municipal Office (4591 Oil Springs Line)	1.52	0	0	< 10					Mar 7th	CC	
		March 4th	7:25 AM	DD	Community Hall (4596 Oil Springs Line)	1.42										
		March 4th	7:50 AM	DD	Youth Centre (4517 Victoria Street)	1.55	0	0	< 10							
		March 4th	7:10 AM	DD	Main Pump Station (2601 Fredrick Street)	1.59										
	Set 2	March 7th	7:30 AM	DD	Community Hall (4596 Oil Springs Line)	1.44										
		March 7th	7:45 AM	DD	Youth Centre (4517 Victoria Street)	1.49										
March 7th		7:15 AM	DD	Main Pump Station (2601 Fredrick Street)	1.53											
Week 2	Set 1	March 11th	7:25 AM	CC	Municipal Office (4591 Oil Springs Line)	1.50	0	0						Mar 14th	CC	
		March 11th	7:40 AM	CC	Community Hall (4596 Oil Springs Line)	1.29										
		March 11th	8:00 AM	CC	Youth Centre (4517 Victoria Street)	1.34	0	0								
		March 11th	7:10 AM	CC	Main Pump Station (2601 Fredrick Street)	1.57										
	Set 2	March 14th	7:30 AM	DD	Community Hall (4596 Oil Springs Line)	1.30										
		March 14th	7:45 AM	DD	Youth Centre (4517 Victoria Street)	1.40										
March 14th		7:15 AM	DD	Main Pump Station (2601 Fredrick Street)	1.44											
Week 3	Set 1	March 18th	7:35 AM	DD	Municipal Office (4591 Oil Springs Line)	1.42	0	0						Mar 21st	CC	
		March 18th	7:20 AM	DD	Community Hall (4596 Oil Springs Line)	1.10										
		March 18th	7:50 AM	DD	Youth Centre (4517 Victoria Street)	1.44	0	0								
		March 18th	7:10 AM	DD	Main Pump Station (2601 Fredrick Street)	1.45										
	Set 2	March 21st	7:25 AM	DD	Community Hall (4596 Oil Springs Line)	1.38										
		March 21st	7:40 AM	DD	Youth Centre (4517 Victoria Street)	1.29										
March 21st		7:10 AM	DD	Main Pump Station (2601 Fredrick Street)	1.49											
Week 4	Set 1	March 25th	7:35 AM	DD	Municipal Office (4591 Oil Springs Line)	1.44								Mar 28th	CC	
		March 25th	7:25 AM	DD	Community Hall (4596 Oil Springs Line)	1.31	0	0								
		March 25th	7:50 AM	DD	Youth Centre (4517 Victoria Street)	1.44	0	0								
		March 25th	7:10 AM	DD	Main Pump Station (2601 Fredrick Street)	1.46										
	Set 2	March 28th	7:35 AM	DD	Community Hall (4596 Oil Springs Line)	1.35										
		March 28th	7:45 AM	DD	Youth Centre (4517 Victoria Street)	1.38										
March 28th		7:10 AM	DD	Main Pump Station (2601 Fredrick Street)	1.48											
Week 5	Set 1				Municipal Office (4591 Oil Springs Line)											
					Community Hall (4596 Oil Springs Line)											
					Youth Centre (4517 Victoria Street)											
					Main Pump Station (2601 Fredrick Street)											
	Set 2				Community Hall (4596 Oil Springs Line)											
					Youth Centre (4517 Victoria Street)											
				Main Pump Station (2601 Fredrick Street)												

Residuals are collected as per O. Reg 170/03 s 7-2 (3) & (4)

Bacteriological samples are collected as per O. Reg 170/03 s 10 (2) & (3)

Oil Springs WD Residuals & Lab Analysis
Apr-25

DD - Derek Daly
CC - Cathy Culnan
RP - Rae Piggott

	Date	Time	Operator	Sampling Location	Chlorine Residual mg/L	E. coli cfu/1 mL	Total Coliform cfu/1 mL	HPC ug/L	HAA ug/L	THM ug/L	pH	Alkalinity mg/L	Lead ug/L	Lab Report Received	Init.	
Week 1	Set 1	Apr 1st	7:10 AM	RP	Municipal Office (4591 Oil Springs Line)	1.38	0	0	< 10					Apr 4th	CC	
		Apr 1st	7:40 AM	RP	Sample Station # 1 (2423 Kelly Rd - Museum)	1.08	0	0	< 10							
		Apr 1st	7:20 AM	RP	Youth Centre (4517 Victoria Street)	1.36										
		Apr 1st	9:00 AM	RP	Hydrant # 34 (Meadowview)	1.56				15.6		7.99	83	0.03		
		Apr 1st	8:00 AM	RP	Hydrant # 38 (Gypsy Flat)	1.09					46	7.86	83	0.46		
	Apr 1st	8:10 AM	RP	Main Pump Station (2601 Fredrick Street)	1.27											
	Set 2	Apr 4th	7:15 AM	RP	Community Hall (4596 Oil Springs Line)	1.30										
		Apr 4th	7:25 AM	RP	Youth Centre (4517 Victoria Street)	1.41										
		Apr 4th	7:05 AM	RP	Main Pump Station (2601 Fredrick Street)	1.56										
	Week 2	Set 1	Apr 8th	7:35 AM	DD	Municipal Office (4591 Oil Springs Line)	1.35								Apr 11th	CC
Apr 8th			7:10 AM	DD	Sample Station # 2 (4898 Oil Springs Line)	1.46	0	0								
Apr 8th			7:50 AM	DD	Youth Centre (4517 Victoria Street)	1.49	0	0								
Apr 8th			7:25 AM	DD	Main Pump Station (2601 Fredrick Street)	1.58										
Set 2		Apr 11th	7:25 AM	DD	Community Hall (4596 Oil Springs Line)	1.04										
		Apr 11th	7:40 AM	DD	Youth Centre (4517 Victoria Street)	1.31										
Week 3	Set 1	Apr 15th	7:25 AM	DD	Municipal Office (4591 Oil Springs Line)	1.20	0	0						Apr 17th	CC	
		Apr 15th	7:10 AM	DD	Sample Station # 1 (2423 Kelly Rd - Museum)	1.25	0	0								
		Apr 15th	7:40 AM	DD	Youth Centre (4517 Victoria Street)	1.14										
		Apr 15th	7:55 AM	DD	Main Pump Station (2601 Fredrick Street)	1.25										
	Set 2	Apr 17th	1:15 PM	RP	Community Hall (4596 Oil Springs Line)	1.20										
		Apr 17th	3:00 PM	RP	Youth Centre (4517 Victoria Street)	1.20										
Week 4	Set 1	Apr 23rd	7:25 AM	RP	Municipal Office (4591 Oil Springs Line)	1.45								Apr 28th	CC	
		Apr 23rd	7:05 AM	RP	Sample Station # 2 (4898 Oil Springs Line)	1.36										
		Apr 23rd	7:40 AM	RP	Youth Centre (4517 Victoria Street)	1.30	0	0								
		Apr 23rd	7:15 AM	RP	Main Pump Station (2601 Fredrick Street)	1.38										
	Set 2	Apr 25th	10:30 AM	RP	Community Hall (4596 Oil Springs Line)	1.21										
		Apr 25th	10:40 AM	RP	Youth Centre (4517 Victoria Street)	1.38										
Week 5	Set 1	Apr 29th	7:35 AM	DD	Municipal Office (4591 Oil Springs Line)	1.52	0	0						May 2nd	CC	
		Apr 29th	7:05 AM	DD	Sample Station # 1 (2423 Kelly Rd - Museum)	1.27										
		Apr 29th	7:50 AM	DD	Youth Centre (4517 Victoria Street)	1.44										
		Apr 29th	7:20 AM	DD	Main Pump Station (2601 Fredrick Street)	1.57										
	Set 2				Community Hall (4596 Oil Springs Line)											
					Youth Centre (4517 Victoria Street)											
				Main Pump Station (2601 Fredrick Street)												

Residuals are collected as per O. Reg 170/03 s 7-2 (3) & (4)

Bacteriological samples are collected as per O. Reg 170/03 s 10 (2) & (3)

Oil Springs WD Residuals & Lab Analysis
May-25

DD - Derek Daly
CC - Cathy Culnan
RP - Rae Piggott

	Date	Time	Operator	Sampling Location	Chlorine Residual mg/L	E. coli cfu/1 mL	Total Coliform cfu/1 mL	HPC ug/L	HAA ug/L	THM ug/L	pH	Alkalinity mg/L	Lead ug/L	Lab Report Received	Init.	
Week 1	Set 1			Municipal Office (4591 Oil Springs Line)											CC	
				Sample Station # 1 (2423 Kelly Rd - Museum)												
				Youth Centre (4517 Victoria Street)												
				Main Pump Station (2601 Fredrick Street)												
	Set 2	May 2nd	7:25 AM	DD	Municipal Office (4591 Oil Springs Line)	1.50										
	May 2nd	7:40 AM	DD	Youth Centre (4517 Victoria Street)	1.43											
	May 2nd	7:10 AM	DD	Main Pump Station (2601 Fredrick Street)	1.53											
Week 2	Set 1	May 6th	7:40 AM	DD	Municipal Office (4591 Oil Springs Line)	1.50								May 9th	CC	
		May 6th	7:10 AM	DD	Sample Station # 2 (4898 Oil Springs Line)	1.52	0	0	< 10							
		May 6th	7:55 AM	DD	Youth Centre (4517 Victoria Street)	1.52	0	0	< 10							
		May 6th	7:25 AM	DD	Main Pump Station (2601 Fredrick Street)	1.57										
	Set 2	May 9th	7:25 AM	DD	Municipal Office (4591 Oil Springs Line)	1.61										
		May 9th	7:40 AM	DD	Youth Centre (4517 Victoria Street)	1.41										
		May 9th	7:10 AM	DD	Main Pump Station (2601 Fredrick Street)	1.61										
Week 3	Set 1	May 13th	7:25 AM	DD	Municipal Office (4591 Oil Springs Line)	1.44	0	0						May 15th	CC	
		May 13th	7:10 AM	DD	Sample Station # 1 (2423 Kelly Rd - Museum)	1.26	0	0								
		May 13th	7:35 AM	DD	Youth Centre (4517 Victoria Street)	1.43										
		May 13th	7:50 AM	DD	Main Pump Station (2601 Fredrick Street)	1.46										
	Set 2	May 16th	7:20 AM	RP	Municipal Office (4591 Oil Springs Line)	1.31										
		May 16th	7:30 AM	RP	Youth Centre (4517 Victoria Street)	1.35										
	May 16th	7:05 AM	RP	Main Pump Station (2601 Fredrick Street)	1.45											
Week 4	Set 1	May 21st	7:40 AM	DD	Municipal Office (4591 Oil Springs Line)	1.51								May 26th	CC	
		May 21st	7:10 AM	DD	Sample Station # 2 (4898 Oil Springs Line)	1.53	0	0								
		May 21st	7:25 AM	DD	Youth Centre (4517 Victoria Street)	1.53	0	0								
		May 21st	7:55 AM	DD	Main Pump Station (2601 Fredrick Street)	1.51										
	Set 2	May 23rd	8:15 AM	DD	Municipal Office (4591 Oil Springs Line)	1.36										
		May 23rd	8:30 AM	DD	Youth Centre (4517 Victoria Street)	1.44										
	May 23rd	8:00 AM	DD	Main Pump Station (2601 Fredrick Street)	1.52											
Week 5	Set 1	May 27th	6:55 AM	CC	Municipal Office (4591 Oil Springs Line)	1.24	0	0						May 30th	CC	
		May 27th	7:40 AM	CC	Sample Station # 1 (2423 Kelly Rd - Museum)	1.08	0	0								
		May 27th	7:15 AM	CC	Youth Centre (4517 Victoria Street)	1.28										
		May 27th	6:40 AM	CC	Main Pump Station (2601 Fredrick Street)	1.42										
	Set 2	May 30th	7:35 AM	DD	Municipal Office (4591 Oil Springs Line)	1.23										
		May 30th	7:50 AM	DD	Youth Centre (4517 Victoria Street)	1.20										
	May 30th	7:20 AM	DD	Main Pump Station (2601 Fredrick Street)	1.33											

Residuals are collected as per O. Reg 170/03 s 7-2 (3) & (4)

Bacteriological samples are collected as per O. Reg 170/03 s 10 (2) & (3)

Oil Springs WD Residuals & Lab Analysis
Jun-25

DD - Derek Daly
CC - Cathy Culnan
RP - Rae Piggott

	Date	Time	Operator	Sampling Location	Chlorine Residual	E. coli	Total Coliform	HPC	HAA	THM	pH	Alkalinity	Lead	Lab Report	Init.	
					mg/L	cfu/1 mL	cfu/1 mL	ug/L	ug/L	ug/L		mg/L	ug/L	Received		
Week 1	Set 1	June 3rd	7:35 AM	DD	Municipal Office (4591 Oil Springs Line)	1.17								June 6th	CC	
		June 3rd	7:10 AM	DD	Sample Station # 2 (4898 Oil Springs Line)	1.31	0	0	< 10							
		June 3rd	7:50 AM	DD	Youth Centre (4517 Victoria Street)	1.10	0	0	< 10							
		June 3rd	7:25 AM	DD	Main Pump Station (2601 Fredrick Street)	1.39										
	Set 2	June 6th	7:45 AM	DD	Black Creek Golf Course (4360 South Plank Rd)	1.21										
		June 6th	7:30 AM	DD	Youth Centre (4517 Victoria Street)	1.21										
		June 6th	7:15 AM	DD	Main Pump Station (2601 Fredrick Street)	1.34										
Week 2	Set 1	June 10th	7:40 AM	DD	Municipal Office (4591 Oil Springs Line)	1.29	0	0						June 12th	CC	
		June 10th	7:10 AM	DD	Sample Station # 1 (2423 Kelly Rd - Museum)	1.13	0	0								
		June 10th	7:55 AM	DD	Youth Centre (4517 Victoria Street)	1.20										
		June 10th	7:25 AM	DD	Main Pump Station (2601 Fredrick Street)	1.38										
	Set 2	June 13th	7:45 AM	RP	Black Creek Golf Course (4360 South Plank Rd)	1.17										
		June 13th	7:30 AM	RP	Youth Centre (4517 Victoria Street)	1.16										
		June 13th	7:15 AM	RP	Main Pump Station (2601 Fredrick Street)	1.40										
Week 3	Set 1	June 17th	7:40 AM	DD	Municipal Office (4591 Oil Springs Line)	1.32								June 20th	CC	
		June 17th	7:10 AM	DD	Sample Station # 2 (4898 Oil Springs Line)	1.34	0	0								
		June 17th	7:55 AM	DD	Youth Centre (4517 Victoria Street)	1.21	0	0								
		June 17th	7:25 AM	DD	Main Pump Station (2601 Fredrick Street)	1.55										
	Set 2	June 20th	7:45 AM	DD	Black Creek Golf Course (4360 South Plank Rd)	1.30										
		June 20th	7:30 AM	DD	Youth Centre (4517 Victoria Street)	1.40										
		June 20th	7:10 AM	DD	Main Pump Station (2601 Fredrick Street)	1.58										
Week 4	Set 1	June 24th	7:40 AM	DD	Municipal Office (4591 Oil Springs Line)	1.37	0	0						June 27th	CC	
		June 24th	7:10 AM	DD	Sample Station # 1 (2423 Kelly Rd - Museum)	1.29	0	0								
		June 24th	7:55 AM	DD	Youth Centre (4517 Victoria Street)	1.38										
		June 24th	7:25 AM	DD	Main Pump Station (2601 Fredrick Street)	1.69										
	Set 2	June 27th	7:45 AM	DD	Black Creek Golf Course (4360 South Plank Rd)	1.26										
		June 27th	7:30 AM	DD	Youth Centre (4517 Victoria Street)	1.40										
		June 27th	7:10 AM	DD	Main Pump Station (2601 Fredrick Street)	1.40										
Week 5	Set 1				Municipal Office (4591 Oil Springs Line)										CC	
					Sample Station # 2 (4898 Oil Springs Line)											
					Youth Centre (4517 Victoria Street)											
					Main Pump Station (2601 Fredrick Street)											
	Set 2				Black Creek Golf Course (4360 South Plank Rd)											
					Youth Centre (4517 Victoria Street)											
					Main Pump Station (2601 Fredrick Street)											

Residuals are collected as per O. Reg 170/03 s 7-2 (3) & (4)

Bacteriological samples are collected as per O. Reg 170/03 s 10 (2) & (3)

Oil Springs WD Residuals & Lab Analysis
Jul-25

DD - Derek Daly
CC - Cathy Culnan
RP - Rae Piggott

	Date	Time	Operator	Sampling Location	Chlorine Residual	E. coli	Total Coliform	HPC	HAA	THM	pH	Alkalinity	Lead	Lab Report Received	Init.	
					mg/L	cfu/1 mL	cfu/1 mL	ug/L	ug/L	ug/L		mg/L	ug/L			
Week 1	Set 1	July 2nd 8:25 AM	DD	Municipal Office (4591 Oil Springs Line)	1.32									July 4th	CC	
		July 2nd 7:55 AM	DD	Sample Station # 2 (4898 Oil Springs Line)	1.52	0	0	< 10								
		July 2nd 8:40 AM	DD	Youth Centre (4517 Victoria Street)		0	0	< 10								
		July 2nd 8:10 AM	DD	Main Pump Station (2601 Fredrick Street)	1.43											
	Set 2	July 4th 10:00 AM	DD	Black Creek Golf Course (4360 South Plank Rd)	1.23											
		July 4th 9:40 AM	DD	Youth Centre (4517 Victoria Street)	1.32											
July 4th 9:15 AM		DD	Main Pump Station (2601 Fredrick Street)	1.34												
Week 2	Set 1	July 8th 8:00 AM	DD	Municipal Office (4591 Oil Springs Line)	1.22	0	0							July 11th	CC	
		July 8th 7:15 AM	DD	Sample Station # 1 (2423 Kelly Rd - Museum)	0.95	0	0			53						
		July 8th 7:30 AM	DD	Hydrant # 34 (Meadowview)	1.30				22.6							
		July 8th 8:20 AM	DD	Youth Centre (4517 Victoria Street)	1.38											
		July 8th 7:45 AM	DD	Main Pump Station (2601 Fredrick Street)	1.45											
	Set 2	July 11th 7:00 AM	CC	Municipal Office (4591 Oil Springs Line)	1.13											
July 11th 7:25 AM		CC	Youth Centre (4517 Victoria Street)	1.31												
July 11th 6:40 AM		CC	Main Pump Station (2601 Fredrick Street)	1.35												
Week 3	Set 1	July 15th 6:40 AM	DD	Municipal Office (4591 Oil Springs Line)	1.13									July 22nd	CC	
		July 15th 6:20 AM	DD	Sample Station # 2 (4898 Oil Springs Line)	1.18	0	0									
		July 15th 6:55 AM	DD	Youth Centre (4517 Victoria Street)	1.15	0	0									
		July 15th 6:30 AM	DD	Main Pump Station (2601 Fredrick Street)	1.24											
	Set 2	July 18th 7:45 AM	DD	Black Creek Golf Course (4360 South Plank Rd)	0.98											
		July 18th 7:30 AM	DD	Youth Centre (4517 Victoria Street)	1.11											
July 18th 7:15 AM		DD	Main Pump Station (2601 Fredrick Street)	1.08												
Week 4	Set 1	July 22nd 7:40 AM	DD	Municipal Office (4591 Oil Springs Line)	0.84	0	0							July 25th	CC	
		July 22nd 7:10 AM	DD	Sample Station # 1 (2423 Kelly Rd - Museum)	0.82											
		July 22nd 7:55 AM	DD	Youth Centre (4517 Victoria Street)	1.15											
		July 22nd 7:25 AM	DD	Main Pump Station (2601 Fredrick Street)	1.31											
	Set 2	July 25th 7:50 AM	DD	Black Creek Golf Course (4360 South Plank Rd)	1.06											
		July 25th 7:30 AM	DD	Youth Centre (4517 Victoria Street)	1.18											
July 25th 7:10 AM		DD	Main Pump Station (2601 Fredrick Street)	1.42												
Week 5	Set 1	July 29th 7:40 AM	DD	Municipal Office (4591 Oil Springs Line) Aug 1st	1.07									Aug 1st	CC	
		July 29th 7:10 AM	DD	Sample Station # 2 (4898 Oil Springs Line)	1.11											
		July 29th 7:55 AM	DD	Youth Centre (4517 Victoria Street)	1.14	0	0									
		July 29th 7:25 AM	DD	Main Pump Station (2601 Fredrick Street)	1.24											
	Set 2				Black Creek Golf Course (4360 South Plank Rd)											
				Youth Centre (4517 Victoria Street)												
				Main Pump Station (2601 Fredrick Street)												

Residuals are collected as per O. Reg 170/03 s 7-2 (3) & (4)

Bacteriological samples are collected as per O. Reg 170/03 s 10 (2) & (3)

Oil Springs WD Residuals & Lab Analysis

Aug-25

DD - Derek Daly
 CC - Cathy Culnan
 RP - Rae Piggott

	Date	Time	Operator	Sampling Location	Chlorine Residual mg/L	E. coli cfu/1 mL	Total Coliform cfu/1 mL	HPC ug/L	HAA ug/L	THM ug/L	pH	Alkalinity mg/L	Lead ug/L	Lab Report Received	Init.	
Week 1	Set 1			Municipal Office (4591 Oil Springs Line)											CC	
				Sample Station # 2 (4898 Oil Springs Line)												
				Youth Centre (4517 Victoria Street)												
				Main Pump Station (2601 Fredrick Street)												
	Set 2	Aug 1st	7:40 AM	DD	Black Creek Golf Course (4360 South Plank Rd)	0.95										
		Aug 1st	7:25 AM	DD	Youth Centre (4517 Victoria Street)	0.99										
		Aug 1st	7:10 AM	DD	Main Pump Station (2601 Fredrick Street)	1.12										
Week 2	Set 1	Aug 6th	7:25 AM	DD	Municipal Office (4591 Oil Springs Line)	1.08	0	0	10					Aug 11th	CC	
		Aug 6th	7:55 AM	DD	Sample Station # 1 (2423 Kelly Rd - Museum)	0.93	0	0	< 10							
		Aug 6th	7:40 AM	DD	Youth Centre (4517 Victoria Street)	1.08										
		Aug 6th	7:15 AM	DD	Main Pump Station (2601 Fredrick Street)	1.12										
	Set 2	Aug 8th	8:20 AM	DD	Municipal Office (4591 Oil Springs Line)	1.02										
		Aug 8th	8:35 AM	DD	Youth Centre (4517 Victoria Street)	1.16										
Week 3	Set 1	Aug 12th	7:40 AM	DD	Municipal Office (4591 Oil Springs Line)	1.11								Aug 18th	CC	
		Aug 12th	7:10 AM	DD	Sample Station # 2 (4898 Oil Springs Line)	1.20	0	0								
		Aug 12th	7:55 AM	DD	Youth Centre (4517 Victoria Street)	1.23	0	0								
		Aug 12th	7:25 AM	DD	Main Pump Station (2601 Fredrick Street)	1.27										
	Set 2	Aug 15th	7:10 AM	CC	Municipal Office (4591 Oil Springs Line)	1.14										
		Aug 15th	6:50 AM	CC	Main Pump Station (2601 Fredrick Street)	1.23										
Week 4	Set 1	Aug 19th	7:20 AM	RP	Municipal Office (4591 Oil Springs Line)	1.12	0	0						Aug 22nd	CC	
		Aug 19th	7:40 AM	RP	Sample Station # 1 (2423 Kelly Rd - Museum)	0.79	0	0								
		Aug 19th	7:55 AM	RP	Youth Centre (4517 Victoria Street)	1.18										
		Aug 19th	7:05 AM	RP	Main Pump Station (2601 Fredrick Street)	1.12										
	Set 2	Aug 22nd	7:45 AM	DD	Black Creek Golf Course (4360 South Plank Rd)	0.99										
		Aug 22nd	7:30 AM	DD	Youth Centre (4517 Victoria Street)	1.12										
Week 5	Set 1	Aug 26th	7:45 AM	DD	Municipal Office (4591 Oil Springs Line) Aug 1st	1.03								Aug 29th	CC	
		Aug 26th	7:15 AM	DD	Sample Station # 2 (4898 Oil Springs Line)	1.01	0	0								
		Aug 26th	8:00 AM	DD	Youth Centre (4517 Victoria Street)	1.01	0	0								
		Aug 26th	7:30 AM	DD	Main Pump Station (2601 Fredrick Street)	1.11										
	Set 2	Aug 29th	7:45 AM	DD	Black Creek Golf Course (4360 South Plank Rd)	0.98										
		Aug 29th	7:30 AM	DD	Youth Centre (4517 Victoria Street)	0.99										
	Aug 29th	7:10 AM	DD	Main Pump Station (2601 Fredrick Street)	1.14											

Residuals are collected as per O. Reg 170/03 s 7-2 (3) & (4)

Bacteriological samples are collected as per O. Reg 170/03 s 10 (2) & (3)

Oil Springs WD Residuals & Lab Analysis
Sep-25

DD - Derek Daly
CC - Cathy Culnan
RP - Rae Piggott

	Date	Time	Operator	Sampling Location	Chlorine Residual	E. coli	Total Coliform	HPC	HAA	THM	pH	Alkalinity	Lead	Chl Kit	Lab Report	Init.	
					mg/L	cfu/1 mL	cfu/1 mL	ug/L	ug/L	ug/L		mg/L	ug/L	#	Received		
Week 1	Set 1	Sept 3rd	6:55 AM	RP	Municipal Office (4591 Oil Springs Line)	1.21								2	Sept 8th	CC	
		Sept 3rd	6:30 AM	RP	Sample Station # 2 (4898 Oil Springs Line)	1.15	0	0	< 10						2		
		Sept 3rd	6:45 AM	RP	Youth Centre (4517 Victoria Street)	1.26	0	0	< 10						2		
		Sept 3rd	7:10 AM	RP	Main Pump Station (2601 Fredrick Street)	1.14									2		
	Set 2	Sept 5th	8:10 AM	RP	Black Creek Golf Course (4360 South Plank Rd)	0.89									2		
		Sept 5th	7:55 AM	RP	Youth Centre (4517 Victoria Street)	1.30									2		
Sept 5th		7:35 AM	RP	Main Pump Station (2601 Fredrick Street)	1.30									2			
Week 2	Set 1	Sept 9th	7:10 AM	RP	Municipal Office (4591 Oil Springs Line)	1.06	0	0						2	Sept 12th	CC	
		Sept 9th	6:55 AM	RP	Sample Station # 1 (2423 Kelly Rd - Museum)	0.67	0	0							2		
		Sept 9th	7:20 AM	RP	Youth Centre (4517 Victoria Street)	1.08									2		
		Sept 9th	6:35 AM	RP	Main Pump Station (2601 Fredrick Street)	1.14									2		
	Set 2	Sept 12th	7:30 AM	RP	Municipal Office (4591 Oil Springs Line)	1.14									2		
		Sept 12th	7:05 AM	RP	Youth Centre (4517 Victoria Street)	0.99									2		
Sept 12th		7:15 AM	RP	Main Pump Station (2601 Fredrick Street)	1.29									2			
Week 3	Set 1	Sept 16th	7:25 AM	RP	Municipal Office (4591 Oil Springs Line)	1.17								2	Sept 19th	CC	
		Sept 16th	7:05 AM	RP	Sample Station # 2 (4898 Oil Springs Line)	1.15	0	0							2		
		Sept 16th	7:35 AM	RP	Youth Centre (4517 Victoria Street)	1.06	0	0							2		
		Sept 16th	7:15 AM	RP	Main Pump Station (2601 Fredrick Street)	1.29									2		
	Set 2	Sept 19th	7:50 AM	DD	Municipal Office (4591 Oil Springs Line)	1.20									2		
		Sept 19th	7:30 AM	DD	Youth Centre (4517 Victoria Street)	1.20									2		
Sept 19th		7:15 AM	DD	Main Pump Station (2601 Fredrick Street)	1.37									2			
Week 4	Set 1	Sept 23rd	7:45 AM	DD	Municipal Office (4591 Oil Springs Line)	1.11	0	0						2	Sept 26th	CC	
		Sept 23rd	7:15 AM	DD	Sample Station # 1 (2423 Kelly Rd - Museum)	1.02									2		
		Sept 23rd	8:00 AM	DD	Youth Centre (4517 Victoria Street)	1.23									2		
		Sept 23rd	7:30 AM	DD	Main Pump Station (2601 Fredrick Street)	1.32									2		
	Set 2	Sept 26th	7:45 AM	DD	Black Creek Golf Course (4360 South Plank Rd)	1.23									1		
		Sept 26th	7:30 AM	DD	Youth Centre (4517 Victoria Street)	1.27									1		
Sept 26th		7:10 AM	DD	Main Pump Station (2601 Fredrick Street)	1.28									1			
Week 5	Set 1	Sept 30th	7:35 AM	DD	Municipal Office (4591 Oil Springs Line) Aug 1st	1.19								2	Oct 3rd	CC	
		Sept 30th	7:05 AM	DD	Sample Station # 2 (4898 Oil Springs Line)	1.16									2		
		Sept 30th	7:50 AM	DD	Youth Centre (4517 Victoria Street)	0.91	0	0							2		
		Sept 30th	7:20 AM	DD	Main Pump Station (2601 Fredrick Street)	1.22									2		
	Set 2				Black Creek Golf Course (4360 South Plank Rd)												
				Youth Centre (4517 Victoria Street)													
				Main Pump Station (2601 Fredrick Street)													

Residuals are collected as per O. Reg 170/03 s 7-2 (3) & (4)

Bacteriological samples are collected as per O. Reg 170/03 s 10 (2) & (3)

Oil Springs WD Residuals & Lab Analysis
Oct-25

DD - Derek Daly
CC - Cathy Culnan
RP - Rae Piggott

	Date	Time	Operator	Sampling Location	Chlorine Residual mg/L	E. coli cfu/1 mL	Total Coliform cfu/1 mL	HPC ug/L	HAA ug/L	THM ug/L	pH	Alkalinity mg/L	Lead ug/L	Chl Kit #	Lab Report Received	Init.		
Week 1	Set 1			Municipal Office (4591 Oil Springs Line)												CC		
				Sample Station # 2 (4898 Oil Springs Line)														
				Youth Centre (4517 Victoria Street)														
				Main Pump Station (2601 Fredrick Street)														
	Set 2	Oct 3rd	7:30 AM	DD	Municipal Office (4591 Oil Springs Line)	1.14									2			
		Oct 3rd	7:45 AM	DD	Youth Centre (4517 Victoria Street)	1.35									2			
Oct 3rd		7:15 AM	DD	Main Pump Station (2601 Fredrick Street)	1.53									2				
Week 2	Set 1	Oct 7th	8:05 AM	DD	Municipal Office (4591 Oil Springs Line)	1.15								2	Oct 14th	CC		
		Oct 7th	7:35 AM	DD	Sample Station # 2 (4898 Oil Springs Line)	1.27	0	0	< 10					2				
		Oct 7th	8:35 AM	DD	Hydrant # 34 (Meadowview)	1.37				16		7.72	84	0.30	2			
		Oct 7th	7:20 AM	DD	Hydrant # 38 (Gypsy Flat - Dead end)	1.02					60	7.71	84	0.35	2			
		Oct 7th	8:20 AM	DD	Youth Centre (4517 Victoria Street)	1.13	0	0	< 10						2			
		Oct 7th	7:50 AM	DD	Main Pump Station (2601 Fredrick Street)	1.30									2			
	Set 2	Oct 10th	7:30 AM	DD	Municipal Office (4591 Oil Springs Line)	1.16									2			
		Oct 10th	7:50 AM	DD	Youth Centre (4517 Victoria Street)	1.19									2			
		Oct 10th	7:10 AM	DD	Main Pump Station (2601 Fredrick Street)	1.20									2			
Week 3	Set 1	Oct 15th	7:35 AM	RP	Municipal Office (4591 Oil Springs Line)	1.13	0	0						1	Oct 20th	CC		
		Oct 15th	7:25 AM	RP	Sample Station # 1 (2423 Kelly Rd - Museum)	0.87	0	0						1				
		Oct 15th	7:05 AM	RP	Youth Centre (4517 Victoria Street)	1.08									1			
		Oct 15th	8:00 AM	RP	Main Pump Station (2601 Fredrick Street)	1.12									1			
	Set 2	Oct 17th	9:15 AM	RP	Municipal Office (4591 Oil Springs Line)	1.36									1			
		Oct 17th	9:05 AM	RP	Youth Centre (4517 Victoria Street)	1.23									1			
Oct 17th		9:25 AM	RP	Main Pump Station (2601 Fredrick Street)	1.34									1				
Week 4	Set 1	Oct 21st	7:45 AM	DD	Municipal Office (4591 Oil Springs Line)	1.12								2	Oct 24th	CC		
		Oct 21st	7:15 AM	DD	Sample Station # 2 (4898 Oil Springs Line)	1.26	0	0						2				
		Oct 21st	8:00 AM	DD	Youth Centre (4517 Victoria Street)	1.08	0	0						2				
		Oct 21st	7:30 AM	DD	Main Pump Station (2601 Fredrick Street)	1.09									2			
	Set 2	Oct 24th	7:30 AM	DD	Municipal Office (4591 Oil Springs Line)	1.25									2			
		Oct 24th	7:45 AM	DD	Youth Centre (4517 Victoria Street)	1.13									2			
Oct 24th		7:15 AM	DD	Main Pump Station (2601 Fredrick Street)	1.26									2				
Week 5	Set 1	Oct 28th	7:50 AM	DD	Municipal Office (4591 Oil Springs Line) Aug 1st	1.64	0	0						1	Oct 31st	CC		
		Oct 28th	7:15 AM	DD	Sample Station # 1 (2423 Kelly Rd - Museum)	0.85	0	0						1				
		Oct 28th	8:10 AM	DD	Youth Centre (4517 Victoria Street)	1.66									1			
		Oct 28th	7:30 AM	DD	Main Pump Station (2601 Fredrick Street)	1.86									1			
	Set 2	Oct 31st	7:20 AM	RP	Municipal Office (4591 Oil Springs Line)	1.71									1			
		Oct 31st	7:10 AM	RP	Youth Centre (4517 Victoria Street)	1.46									1			
Oct 31st		7:30 AM	RP	Main Pump Station (2601 Fredrick Street)	1.51									1				

Residuals are collected as per O. Reg 170/03 s 7-2 (3) & (4)

Bacteriological samples are collected as per O. Reg 170/03 s 10 (2) & (3)

Oil Springs WD Residuals & Lab Analysis
Nov-25

DD - Derek Daly
CC - Cathy Culnan
RP - Rae Piggott

	Date	Time	Operator	Sampling Location	Chlorine Residual	E. coli	Total Coliform	HPC	HAA	THM	pH	Alkalinity	Lead	Chl Kit	Lab Report	Init.	
					mg/L	cfu/1 mL	cfu/1 mL	ug/L	ug/L	ug/L		mg/L	ug/L	#	Received		
Week 1	Set 1	Nov 4th	7:40 AM	DD	Municipal Office (4591 Oil Springs Line)	1.16								2	Nov 7th	CC	
		Nov 4th	7:10 AM	DD	Sample Station # 2 (4898 Oil Springs Line)	1.48	0	0	< 10					2			
		Nov 4th	7:55 AM	DD	Youth Centre (4517 Victoria Street)	1.79	0	0	< 10					2			
		Nov 4th	7:25 AM	DD	Main Pump Station (2601 Fredrick Street)	1.76								2			
	Set 2	Nov 7th	7:30 AM	RP	Municipal Office (4591 Oil Springs Line)	1.63								1			
		Nov 7th	7:55 AM	RP	Youth Centre (4517 Victoria Street)	1.56								1			
Nov 7th		7:05 AM	RP	Main Pump Station (2601 Fredrick Street)	1.47								1				
Week 2	Set 1	Nov 12th	7:40 AM	DD	Municipal Office (4591 Oil Springs Line)	1.39	0	0						2	Nov 17th	CC	
		Nov 12th	7:10 AM	DD	Sample Station # 2 (4898 Oil Springs Line)	1.43	0	0						2			
		Nov 12th	7:55 AM	DD	Youth Centre (4517 Victoria Street)	1.51								2			
		Nov 12th	7:25 AM	DD	Main Pump Station (2601 Fredrick Street)	1.48								2			
	Set 2	Nov 14th	9:45 AM	CC	Municipal Office (4591 Oil Springs Line)	1.75								2			
		Nov 14th	10:30 AM	CC	Youth Centre (4517 Victoria Street)	1.48								2			
Nov 14th		10:10 AM	CC	Main Pump Station (2601 Fredrick Street)	1.93								2				
Week 3	Set 1	Nov 18th	7:36 AM	RP	Municipal Office (4591 Oil Springs Line)	1.46								1	Nov 21st	CC	
		Nov 18th	7:25 AM	RP	Sample Station # 1 (2423 Kelly Rd - Museum)	1.23	0	0						1			
		Nov 18th	7:08 AM	RP	Youth Centre (4517 Victoria Street)	1.61	0	0						1			
		Nov 18th	8:04 AM	RP	Main Pump Station (2601 Fredrick Street)	1.43								1			
	Set 2	Nov 21st	7:20 AM	RP	Municipal Office (4591 Oil Springs Line)	1.67								1			
		Nov 21st	7:05 AM	RP	Youth Centre (4517 Victoria Street)	1.79								1			
Nov 21st		7:40 AM	RP	Main Pump Station (2601 Fredrick Street)	1.84								1				
Week 4	Set 1	Nov 25th	7:25 AM	DD	Municipal Office (4591 Oil Springs Line)	1.58	0	0						1	Nov 28th	CC	
		Nov 25th	7:10 AM	DD	Sample Station # 2 (4898 Oil Springs Line)	1.22	0	0						1			
		Nov 25th	8:10 AM	DD	Youth Centre (4517 Victoria Street)	1.45								1			
		Nov 25th	7:40 AM	DD	Main Pump Station (2601 Fredrick Street)	1.54								1			
	Set 2	Nov 28th	7:15 AM	DD	Municipal Office (4591 Oil Springs Line)	1.57								1			
		Nov 28th	7:30 AM	DD	Youth Centre (4517 Victoria Street)	1.46								1			
Nov 28th		7:00 AM	DD	Main Pump Station (2601 Fredrick Street)	1.51								1				
Week 5	Set 1				Municipal Office (4591 Oil Springs Line) Aug 1st												
					Sample Station # 1 (2423 Kelly Rd - Museum)												
					Youth Centre (4517 Victoria Street)												
					Main Pump Station (2601 Fredrick Street)												
	Set 2				Municipal Office (4591 Oil Springs Line)												
					Youth Centre (4517 Victoria Street)												
				Main Pump Station (2601 Fredrick Street)													

Residuals are collected as per O. Reg 170/03 s 7-2 (3) & (4)

Bacteriological samples are collected as per O. Reg 170/03 s 10 (2) & (3)

Oil Springs WD Residuals & Lab Analysis
Dec-25

DD - Derek Daly
CC - Cathy Culnan
RP - Rae Piggott

	Date	Time	Operator	Sampling Location	Chlorine Residual mg/L	E. coli cfu/1 mL	Total Coliform cfu/1 mL	HPC ug/L	HAA ug/L	THM ug/L	pH	Alkalinity mg/L	Lead ug/L	Chl Kit #	Lab Report Received	Init.	
Week 1	Set 1	Dec 2nd	7:45 AM	DD	Municipal Office (4591 Oil Springs Line)	1.55								1	Dec 5th	CC	
		Dec 2nd	7:25 AM	DD	Sample Station # 1 (2423 Kelly Rd - Museum)	1.53	0	0	< 10						1		
		Dec 2nd	8:00 AM	DD	Youth Centre (4517 Victoria Street)	1.54	0	0	< 10						1		
		Dec 2nd	8:15 AM	DD	Main Pump Station (2601 Fredrick Street)	1.63									1		
	Set 2	Dec 5th	6:20 AM	CC	Municipal Office (4591 Oil Springs Line)	1.57									2		
		Dec 5th	6:40 AM	CC	Youth Centre (4517 Victoria Street)	1.50									2		
Dec 5th		6:05 AM	CC	Main Pump Station (2601 Fredrick Street)	1.72									2			
Week 2	Set 1	Dec 9th	7:25 AM	RP	Municipal Office (4591 Oil Springs Line)	1.90	0	0						1	Dec 12th	CC	
		Dec 9th	7:05 AM	RP	Sample Station # 2 (4898 Oil Springs Line)	1.28	0	0						1			
		Dec 9th	7:35 AM	RP	Youth Centre (4517 Victoria Street)	1.83									1		
		Dec 9th	7:15 AM	RP	Main Pump Station (2601 Fredrick Street)	1.70									1		
	Set 2	Dec 12th	7:15 AM	DD	Municipal Office (4591 Oil Springs Line)	1.83									2		
		Dec 12th	7:45 AM	DD	Youth Centre (4517 Victoria Street)	1.70									2		
Dec 12th		7:30 AM	DD	Main Pump Station (2601 Fredrick Street)	1.70									2			
Week 3	Set 1	Dec 16th	6:40 AM	DD	Municipal Office (4591 Oil Springs Line)	1.64								2	Dec 19th	CC	
		Dec 16th	6:10 AM	DD	Sample Station # 1 (2423 Kelly Rd - Museum)	1.53	0	0						2			
		Dec 16th	6:55 AM	DD	Youth Centre (4517 Victoria Street)	1.75	0	0						2			
		Dec 16th	6:25 AM	DD	Main Pump Station (2601 Fredrick Street)	1.79								2			
	Set 2	Dec 19th	7:25 AM	DD	Municipal Office (4591 Oil Springs Line)	1.69								1			
		Dec 19th	7:40 AM	DD	Youth Centre (4517 Victoria Street)	1.70								1			
Dec 19th		7:10 AM	DD	Main Pump Station (2601 Fredrick Street)	1.76								1				
Week 4	Set 1	Dec 22nd	7:40 AM	DD	Municipal Office (4591 Oil Springs Line)	1.70	0	0						1	Dec 29th	CC	
		Dec 22nd	7:10 AM	DD	Sample Station # 2 (4898 Oil Springs Line)	1.30								1			
		Dec 22nd	7:55 AM	DD	Youth Centre (4517 Victoria Street)	1.90								1			
		Dec 22nd	7:25 AM	DD	Main Pump Station (2601 Fredrick Street)	1.56								1			
	Set 2	Dec 24th	8:30 AM	DD	Municipal Office (4591 Oil Springs Line)	1.60								1			
		Dec 24th	8:45 AM	DD	Youth Centre (4517 Victoria Street)	1.66								1			
Dec 24th		8:15 AM	DD	Main Pump Station (2601 Fredrick Street)	1.85								1				
Week 5	Set 1	Dec 29th	7:30 AM	DD	Municipal Office (4591 Oil Springs Line) Aug 1st	1.67								1	Jan 2nd		
		Dec 29th	8:00 AM	DD	Sample Station # 1 (2423 Kelly Rd - Museum)	1.47								1			
		Dec 29th	8:15 AM	DD	Youth Centre (4517 Victoria Street)	1.67	0	0						1			
		Dec 29th	7:45 AM	DD	Main Pump Station (2601 Fredrick Street)	1.72								1			
	Set 2				Municipal Office (4591 Oil Springs Line)												
					Youth Centre (4517 Victoria Street)												
				Main Pump Station (2601 Fredrick Street)													

Residuals are collected as per O. Reg 170/03 s 7-2 (3) & (4)

Bacteriological samples are collected as per O. Reg 170/03 s 10 (2) & (3)